

MOBILE FOOD TRUCK CHECK LIST – No Kitchen Suppression System:

In order to operate a mobile food truck in the City of Welland, the following criteria must be met:

Contact Welland Fire Prevention if you have any questions: 905-735-1700 ext 2403

- **A Business Licence must be obtained from the City of Welland.**
- A 5lb. multi-purpose fire extinguisher must be present and easily accessible. The extinguisher must have an inspection tag to indicate inspection within last year by certified technician. (see attached appendix A)
- If there is propane used, a current (within past year) TSSA certificate for mobile food vehicles prepared by a licensed gas fitter (see attached appendix B)
- A qualified person will conduct all tank connections and conduct soap test on all connections prior to use.
- Propane tanks to be stored in compliance with TSSA regulations.
- Competent adult shall maintain and supervise cooking at all times.

Food truck operator:

Name:

Contact #:

Address:

The above criteria have been completed: _____
Signature Date

Appendix A: Multipurpose and K Class Fire Extinguishers



A 5lb fire extinguisher is required – 2A:10B:C or 3A:40B:C



“A” TRASH-WOOD-PAPER



“B” LIQUIDS (cooking liquids, oil, gasoline, kerosene)



“C” ELECTRICAL EQUIPMENT (live electrical equipment)

A- and B- rated fire extinguishers use numbers to show how large a fire they can fight. A fire extinguisher with a 1A rating is equivalent to 1.25 gallons of water. Eg. 2A rating equals 2.5 gallons of water and a 4A rating equals 5 gallons of water.

B-rated fire extinguishers are numbered in 10s. Eg. An extinguisher with a 10B rating can cover 10 square feet, an extinguisher with a 20B rating can cover 20 square feet.

Appendix B – Sample TSSA Annual Inspection Report

Attachment #2

| | | |
|---|---|-----------------------|
|  | MOBILE FOOD SERVICE EQUIPMENT ANNUAL INSPECTION CERTIFICATE FOR MFSE'S | Document No: MFSE-002 |
| | | Date: June 1, 2013 |
| | | Page: 1 of 1 |

Equipment Type: Self-propelled Vehicle Towed Trailer or Cart Portable Cart

Equipment Identification (Licence Plate No. or V.I.N.) _____

Owner _____ Tel. No. _____

Address _____

FSD Label No. (If built after Feb. 13, 2006) _____

The following checklist is intended as a minimum. Additional inspection tests may be necessary to ensure safe operation.

| | Yes | No | N/A |
|--|-----|----|-----|
| Have the required DANGER labels been affixed? | | | |
| If built after Feb. 13, 2006, is a TSSA FSD Label and MFSE rating plate in place? | | | |
| If the equipment is on 4 wheels, are 2 wheels lockable to prevent movement when in service? | | | |
| Are the gas components (hoses, regulators, etc.) approved for the service? | | | |
| Are the gas lines, fittings and hoses in good condition? | | | |
| Is the propane cylinder properly supported and secured? | | | |
| If the cylinder is in a cabinet, is it well ventilated? | | | |
| Are the clearances to combustibles maintained? | | | |
| Are the appliances in good working condition? | | | |
| Is the equipment and all its components leak tight? | | | |
| Are the supply pressures to the equipment and appliances set properly? | | | |
| Do all the appliances ignite properly? | | | |
| Does the owner/operator understand the operations and responsibilities outlined in the Danger labelling? | | | |
| Have any deficiencies found been corrected and is the equipment safe to operate? | | | |

To pass all answers must be either YES or N/A

| | | |
|---------------------------------|-----------------------------|------|
| Certificate Holder Name (Print) | TSSA Certificate Holder No. | Date |
|---------------------------------|-----------------------------|------|

Re-Inspection Required 1 Year from the above date.
This Certification shall be kept available with the equipment covered at all times.

| |
|----------|
| Comments |
|----------|

