

MOBILE FOOD TRUCK CHECK LIST – Electric Only:

In order to operate a mobile food truck in the City of Welland, the following criteria must be met:

Contact Welland Fire Prevention if you have any questions: 905-735-1700 ext 2403

- **A Business Licence must be obtained from the City of Welland.**
- A 5lb. multi-purpose fire extinguisher must be present and easily accessible. The extinguisher must have an inspection tag to indicate inspection within last year by certified technician. (see attached appendix A)
- Electrical panel shall be labelled.
- All electrical appliances/wiring are in good repair.
- No cooking that produces grease laden vapours is taking place.
- Competent adult shall maintain and supervise operations at all times.

Food truck operator:

Name:

Contact #:

Address:

The above criteria have been completed: _____
Signature Date

Appendix A: Multipurpose and K Class Fire Extinguishers



A 5lb fire extinguisher is required – 2A:10B:C or 3A:40B:C



“A” TRASH–WOOD–PAPER



“B” LIQUIDS (cooking liquids, oil, gasoline, kerosene)



“C” ELECTRICAL EQUIPMENT (live electrical equipment)

A- and B- rated fire extinguishers use numbers to show how large a fire they can fight. A fire extinguisher with a 1A rating is equivalent to 1.25 gallons of water. Eg. 2A rating equals 2.5 gallons of water and a 4A rating equals 5 gallons of water.

B-rated fire extinguishers are numbered in 10s. Eg. An extinguisher with a 10B rating can cover 10 square feet, an extinguisher with a 20B rating can cover 20 square feet.