

**TABLE 7.4.0.A  
GENERAL PROVISIONS FOR POOL ENCLOSURES**

PROVISIONS	ALL PROPERTIES
i. <u>Minimum</u> Height of Fences and Gates	1.5 m (5 ft.) or 1.8 m (6 ft.)
ii. <u>Maximum</u> Clearance Between Bottom of Fence and Grade	100 mm (4 in.)

**TABLE 7.4.1.A  
WOOD FENCE CONSTRUCTION FOR POOL ENCLOSURES**

PROVISIONS	ALL PROPERTIES
i. Horizontal Rail <u>Minimum</u> Size	38 mm (1-1/2 in. x 89 mm (3-1/2 in.))
ii. If <u>Minimum</u> Vertical Spacing Between Horizontal Railings	0.9 m (35.4 in.)
iii. Then <u>Maximum</u> Spacing Between Vertical Boards	100 mm (4 in.)
iv. If <u>Minimum</u> Vertical Spacing Between Horizontal Railings	Less than 0.9 m (35.4 in.)
v. Then <u>Maximum</u> Spacing Between Vertical Boards	38 mm 1-1/2 in.)
vi. Vertical Board <u>Minimum</u> Size	19 mm (3.4 in.) x 89 mm (3-1/2 in.)
vii. Fence Post <u>Maximum</u> Spacing	2.4 m (8 ft.)
viii. <u>Minimum</u> Size of Fence Posts	89 mm (3-1/2 in.) x 89 mm (3-1/2 in.)
ix. <u>Minimum</u> Depth Below Grade Of Imbedded Fence Posts	1.2 m (4 ft.)

**TABLE 7.4.2.A  
METAL AND WROUGHT IRON FENCE CONSTRUCTION FOR POOL ENCLOSURES**

PROVISIONS	ALL PROPERTIES
i. <u>Minimum</u> Vertical Spacing Between Horizontal Railing	0.9 m (35.4 in.)
ii. Vertical Railing <u>Maximum</u> Spacing	100 mm (4 in.)
iii. <u>Minimum</u> Depth Below Grade Of Imbedded Fence Posts	1.2 m (4 ft.)

**TABLE 7.4.3.A**

**CHAIN LINK FENCE CONSTRUCTION FOR POOL ENCLOSURES**

<b>PROVISIONS</b>	<b>ALL PROPERTIES FOR POSTS SPACED MAXIMUM 2.4 M (8 FT.)</b>	<b>ALL PROPERTIES FOR POSTS SPACES MAXIMUM 3 M (10 FT.)</b>
<u>Minimum</u> Vertical Spacing Between Horizontal Railings	0.9 m (35.4 in.)	0.9 m (35.4 in.)
<u>Maximum</u> Chain Link Mesh Size For 1.5 m (5 ft.) Fencing	38 mm (1-1/2 in.)	38 mm (1-1/2 in.)
<u>Maximum</u> Chain Link Mesh Size For 1.8 m (6 ft.) Fencing	38 mm (1-1/2 in.) or 50 mm (2 in.)	38 mm (1-1/2 in.) or 50 mm (2 in.)
<u>Minimum</u> Diameter/Gauge Of Mesh Including Vinyl Covering	2.6 mm diameter (No. 11 gauge) or 2 mm diameter (No. 14 gauge) with vinyl covering forming a total combined thickness of 2.6 mm (No. 11 gauge)	2.6 mm diameter (No. 11 gauge) or 2 mm diameter (No. 14 gauge) with vinyl covering forming a total combined thickness of 2.6 mm (No. 11 gauge)
<u>Minimum</u> Diameter Gate And Terminal Posts	47.5 mm (1-2/7 in.)	47.5 mm (1-7/8 in.)
<u>Minimum</u> Depth Below Grade Of Imbedded Fence Posts	The steel fence post will be a minimum of 0.76 cm (2 ft. 6 in.) imbedded in a concrete footing which has a diameter of 20.32 cm (8 in.) and a depth of 1.2 m (4 ft.). NOTE: The top of concrete footing may be below grade level 10.175 cm to 20.35 cm (4 in. to 8 in.)	The steel fence post will be a minimum of 0.76 cm (2 ft. 6 in.) imbedded in a concrete footing which has a diameter of 20.32 cm (8 in.) and a depth of 1.2 m (4 ft.). NOTE: The top of concrete footing may be below grade level 10.175 cm to 20.35 cm (4 in. to 8 in.)
<u>Minimum</u> Diameter For Intermediate Posts	38 mm (1-1/2 in.)	47.5 mm (1-7/8 in.)
<u>Minimum</u> Diameter Top Rail	32 mm (1-1/4 in.)	41.275 mm (1-5/8 in.)
<u>Minimum</u> Diameter Bottom Wire	3.7 mm (No. 9 gauge)	3.7 mm (No. 9 gauge)
<u>Minimum</u> Diameter Gate Frame – Pipe	32 mm (1-1/4 in.)	32 mm (1-1/4 in.)